

Submit Form To:

Amarillo Field Office
ATTN: Assistant Field Manager for Operations
801 S. Fillmore, Suite 500
Amarillo, TX 79101

Cliffside Gas Plant Status Report

Date & Time of Outage: March 13, 2021 at 1400 CT

Cause of Outage: Planned Maintenance

Factors Causing Restart:

- Planned Maintenance; Scheduled for 10-13 days

Current Status:

- The plant was shut down at 2:00 PM Saturday March 13 to allow for process Fluids were drained from the Cold box on Saturday and a nitrogen purge of the system was started Sunday March 14.

Forecast:

- Reporting will be updated as milestones are completed.

Pipeline Pressure at Cliffside: At 1300 (CT), Tuesday, March 16, 2021 = 1,242 psig

Next Report: 0800 (CT), Wednesday, March 17, 2021

Points of Contact: Samuel R.M. Burton, Field Manager, at 806-356-1002
Email sburton@blm.gov

Mark Musick, CHEU Foreman, at 806-477-1256
Email mmusick@blm.gov