

Woods, Penelope D

From: Oppenborn, Tod Civ USAF ACC 99 CES/CEAO <Tod.Oppenborn@nellis.af.mil>
Sent: Tuesday, October 02, 2012 3:27 PM
To: Woods, Penelope D
Subject: Pipeline Project EIS Comments
Signed By: OPPENBORN.TOD.NMN.1222853148

Ms Penny,

Below you will find comments we would like to submit concerning the comment call for the FEIS.

- Page 2-25, Figure 2.5-4 It appears the 230-kV Power Pole is less than 100 feet high. Any poles higher than 100 feet need to be lighted as they intrude into the Desert Military Operations Area and the NTTR has aircraft that fly at 100 feet AGL and above.
- Supersonic operations will occur during and after the construction of the project.

If you have any questions, please feel free to contact me at 702 652-9366.

Thanks
Tod